



HIGH-ACCURACY OPTIONS FOR COUPLING CAPACITOR VOLTAGE TRANSFORMERS


Product Bulletin HV-11-PB013r2

As the need to perform revenue metering at transmission level voltages increases, the metering accuracy of instrument transformers need to be as precise as possible.

Areva is able to supply CCVTs type OTCF with accuracy ratings surpassing those listed in IEEE C57.13-1993.

Typical high-accuracy ratings such as 0.15 WXYZ are available on all designs. Other ratings surpassing the 0.15% class or with higher burden ratings can also be provided upon special request.

0.3 Class versus 0.15 Class



AREVA T&D

Areva Waynesboro
One Areva Avenue
Waynesboro, Ga. 30830
Tel.: (706) 554-8800
Fax: (706) 554-8808
usitrinfo@areva-td.com
itr-us.areva-td.com